



Certificate of Compliance

Certificate: 2248838 **Master Contract:** 154942 (026894_0_000)

Project: 70127166 **Date Issued:** 2017-03-31

Issued to: Peter Paul Electronics Company Incorporated
480 John Downey Dr.
New Britain, Connecticut 06050
USA
Attention: Paul J. Molinari Sr.

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Vajira Sarathchandra
Vajira Sarathchandra

PRODUCTS

CLASS - C337103 - VALVES (GAS)-Automatic - For Gas Appliances

CLASS - C337183 - VALVES (GAS)-Automatic-For Gas Appliances-Certified to U.S. Standards

MODELS:

E22Z0196YCCP 24/DC

E22Z0197YCCP 120/60

E22Z0198YCCP 12/DC

Maximum Operating Temperature: 100°C

Minimum Operating Temperature: -40°C

APPLICABLE REQUIREMENTS

ANSI Z21.21-2015/CSA 6.5-2015 - Automatic Valves for Gas Appliances



Supplement to Certificate of Compliance

Certificate: 2248838

Master Contract: 154942 (026894_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70127166	2017-03-31	Update maximum operating temperature of E22Z019(6,7,8)YCCP Series valves to 100°C.
2708076	2014-05-23	Original certification of Series 80 2 Way Normally Closed valve. 1/2"
2474448	2011-11-24	Transfer file from ACL Manufacturing Inc. to Peter Paul Electronics Co. Inc. Update model names. Only 1/4" size are activated.
2248838	2010-12-21	Initial Certification of 1/4" and 3/8" Safety Shut-Off Valves, C/I rated, Model: ACL-SV-SSO-(2, 3)-(12, 24, 120)-XXXXXX. Standard used: ANSI Z21.21-2005/CSA 6.5-2005